


Govt. Of Bihar
 DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
 Public Health Engineering Department
 P.H. DIVISION, GAYA

Physico-Chemical Examination Report of Drinking Water Sample of Gaya

Sample Collected By : Shatabdi Public School Staff		Location Details Shatabdi public school, katari Hill Road, Gaya										Sample Received on : 09.04.2024										
Sample ID	GAVA/W/24-25/96											Reporting Date : 18.04.2024		Desirable Limit		Permissible Limit in absence of alternate source (S:10500:2012)						
Turb.	0.86	Conductivity	610	TDS	396	Hardness	212	Calcium	49.70	Magnesium	21.38	Chloride	35.99	Alkalinity	228	Fluoride	0.78	PH	7.18	Remarks		
	1.00		-		500		200		75		30		250		200		1.00		6.5-			
	NTU				(mg/l)		(mg/l)		(mg/l)		(mg/l)		(mg/l)		(mg/l)		(mg/l)		8.5			
	5.00		-		2000		600		200		100		1000		600		1.50		NR			
	NTU				(mg/l)		(mg/l)		(mg/l)		(mg/l)		(mg/l)		(mg/l)		(mg/l)					


*NR-No Relaxation.

जल नमूना को तुरंत निरीक्षण 9-4-24
 सेक्टर सिस्टम से द्वारा किया गया है ।


 18/04/2024
 Chemist
 P.H. Division, Gaya

Attested


Principal
 Shatabdi Public School, Gaya



Secretary
 Shatabdi Public School, Gaya